



Date Submitted: 6/27/2016

## Water Use Efficiency Annual Performance Report - 2015

WS Name: YAK CO - CREWPOR

Water System ID# : 16242

WS County: YAKIMA

Report submitted by: *Bill Trout*

### Meter Installation Information:

Estimate the percentage of metered connections: 100%

If not fully metered - Current status of meter installation:

### Production, Authorized Consumption, and Distribution System Leakage Information:

12-Month WUE Reporting Period: 01/01/2015 To 12/31/2015

Incomplete or missing data for the year? No

If yes, explain:

### Distribution System Leakage Summary:

Total Water Produced and Purchased (TP) – Annual Volume	7,955,000 gallons
Authorized Consumption (AC) – Annual Volume	7,326,840 gallons
Distribution System Leakage – Annual Volume TP – AC	628,160 gallons
Distribution System Leakage – Percent DSL = [(TP – AC) / TP] x 100	7.9 %
3-year annual average	8.2 %

### Goal-Setting Information:

Date of Most Recent Public Forum: 12/31/2009 Has goal been changed since last performance report? No

Note: Customer goal must be re-established every 6 years through a public process

### WUE Goals:

Customer Goal (Demand Side):

*Maintain distribution system leakage at less than 10 percent based on a 3-year rolling average. Reduce average day and peak month demands per single-family residence by 3 percent based on the average of demands over the next 6-year planning period (2009-2014) as compared to the average over the previous 6-year planning period (2003-2008) 1.*

### Describe Progress in Reaching Goals:

Customer (Demand Side) Goal Progress:

1. Educating customers about water use efficiency practices.
2. WUE measures currently being implemented include billing customers on an inclining block rate structure, notifying customers when an unusually high bill is discovered or when the meter leak detector indicates a leak, and providing water conservation tips in the CCR's.
3. There was a 5.4% decrease in demands from 2014 and 2015
4. There was a 12.9% decrease in peak month demand from 2014 and 2015

#### **Additional Information Regarding Supply and Demand Side WUE Efforts**

Include any other information that describes how you and your customers use water efficiently:

*No appreciable amount of water was saved last year by supply side measures. System leakage was 7.9 in 2015, 8.7% in 2014, 8.0% in 2013, 9.1% in 2012, 8.1% in 2011. The system is meeting its goal. No supply side WUE measures have been implemented at this time.*

*Demand Side Goal Progress:*

*Demand decreased by approximately 5.4% from 2014 to 2015. WUE measures currently being implemented include customers on an inclining block rate structure, notifying customers when an unusually high bill is discovered or when the meter leak detector indicates a leak, and providing water conservation tips in CCR's.*

**Do not mail, fax, or email this report to DOH**