

WATER QUALITY DATA GALA ESTATES WATER

The data presented in the water quality data table is from testing done between January 2012 and December 2020. The State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Gala Estates Water System tests for 16 IOCs (inorganic contaminants), 32 SOCs (synthetic organic contaminants), and 19 VOCs (volatile organic contaminants). Below are the substances that were detected in your drinking water.

Contaminant (units)	MCL	MCLG	Maximum Results for Gala Water System	Sample Date	Violation	Typical Source of Contaminant
Inorganic Contaminants						
Fluoride (ppm)	4	4	0.83	8/6/2012	No	Erosion of Natural Deposits
Sodium (ppm)	N/A	N/A	27.3	8/6/2012	No	Erosion of Natural Deposits
Conductivity (ppm)	700	700	232	8/6/2012	No	Erosion of Natural Deposits
Nitrate (ppm)	10	10	0.10	7//272020	No	Erosion of Natural Deposits
Arsenic (ppb)	10	10	0.0041	8/6/2012	No	Erosion of Natural Deposits
Lead and Copper						
Lead (ppm)	0.015	0.015	0.0001	7/28/2020	No	Corrosion of Household Plumbing

Contaminant (units)	MCL	MCLG	Maximum Results for Gala Water System	Sample Date	Violation	Typical Source of Contaminant
Copper (ppm)	1.3	1.3	0.064	7/28/2020	No	Corrosion of Household Plumbing
Trihalomethanes (THM) Disinfection by-products						
Total Trihalomethanes (ppb)	80	80	9.6	6/19/2018	No	Chlorine By Product
Haloacetic Acids: (HAA's) Disinfection by-products						
HAA's Total (ppb)	60	60	2.2	6/19/2018	No	Chlorine By Product

In Washington State, lead in drinking water comes primarily from materials and components used in household plumbing. The more time water has been sitting in pipes, the more dissolved metals, such as lead, it may contain. Elevated levels of lead can cause serious health problems, especially in pregnant women and young children. To help reduce potential exposure to lead: for any drinking water tap that has not been used for 6 hours or more, flush water through the tap until the water is noticeably colder before using for drinking or cooking. You can use the flushed water for watering plants, washing dishes, or general cleaning. Only use water from the cold-water tap for drinking, cooking, and especially for making baby formula. Hot water is likely to contain higher levels of lead. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water is available from EPA's Safe Drinking Water Hotline at 1-800-426-4791 or online at <http://www.epa.gov/safewater/lead>.

About Arsenic: While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at higher concentrations and is linked to other health effects such as skin damage and circulatory problems.